

Marking

The product is to be marked at the factory. The marking consists of a label on every product supplied and includes:

Holder	Svalson Safety AB
Manufacturing place	Öjebyn
Product type designation	SV-E60
Consecutive manufacture no./date of production	nr/datum
Type approval number	0305/01
Boverket's registered trade mark	†
RISE Accreditation number	1002
Inspection body	RISE

Basis for approval

Report No. P102021 from SP.

Drawings according to "Ritningsförteckning för Brandlucka SV E-60", dated 2007-01-15.

Comments

The fire resistance glass Pyran S is supposed to be CE-marked and fulfil the requirements for fire resistance class E 60 according to EN 13501-2.

Other relevant properties of the sliding window, for example safety in use, are covered by the CE-marking of the product.

According to Boverket Building Regulations (BBR) chapter 5:534, windows and doors in a separating structure shall be designated so that the fire compartment boundaries are maintained. Therefore, the closing of the sliding window at a fire must be ensured, either by connection to an automatic fire alarm or by some other closing function, for example closing by timer or an instruction close to the sliding window with information that the sliding window must be closed when not in use.

Associated documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2022-01-16.

Validity

Valid through 2027-01-15.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved product with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.



Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.